



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: C.A.R.D. Head Starts

School: Bartlesville Early Head Start

Sampling Date: 9/18/2024

Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at C.A.R.D. Head Starts - Bartlesville Early Head Start on September 18, 2024. Overall, eight (8) outlets were tested resulting in a total of sixteen (16) samples being sent to the lab.

- Fourteen (14) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- One (1) sample had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen faucet in facility kitchen	<1.0	<1.0	N/A
1-1-KIT-IM1	Manitowoc ice machine in facility kitchen	<1.0	<1.0	N/A
1-1-2-CF1	Room #2 classroom faucet, left side	<1.0	<1.0	N/A
1-1-2-CF2	Room #2 classroom faucet, right side	<1.0	<1.0	N/A
1-1-1-CF1	Room #1 classroom faucet	<1.0	<1.0	N/A
1-1-1-CF2	Room #1 classroom faucet, handwash sink	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-HS-CF2	Head Start Main classroom faucet, right side	7.1	<1.0	
High Detection (≥15.0 µg/L)				
1-1-HS-CF1	Head Start Main classroom faucet, left side	19.1	<1.0	