



OKLAHOMA DRINKING WATER  
**LEAD TESTING**  
 IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Enid Public Schools  
 School: Carver Early Childhood Center  
 Sampling Date: 8/13/2024  
 Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Enid Public Schools - Carver Early Childhood Center on August 13, 2024. Overall, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- One (1) sample had no detectable level of lead.
- Nine (9) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
1-1-FOY-WC1	Oasis water cooler in foyer	1.4	2.2	
1-1-HALL-WC1	Oasis water cooler in hall next to Rm 111	1.4	3.0	
1-1-CAFÉ-KF1	Kitchen faucet in cafeteria	1.6	4.3	
1-1-KIT-KF1	Kitchen faucet in kitchen next to teachers' lounge	7.1	<1.0	
1-1-HALL-WC2	Oasis water cooler to right of Rm 102	10.7	5.3	