



District: Stonewall Public Schools
 School: Stonewall Elementary and High School
 Sampling Dates: 10/21/2021, 11/18/2022
 Status: Completed Sampling

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Stonewall Public Schools - Stonewall Elementary and High School. The initial sampling event occurred on October 21, 2021. The resampling event occurred on November 18, 2022.

In the initial sampling, twenty-three (23) outlets were tested resulting in a total of forty-six (46) samples being sent to the lab.

- Twenty-five (25) samples had no detectable level of lead.
- Twenty (20) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- One (1) sample had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Eight (8) samples had no detectable level of lead.
- Two (2) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. An index of buildings tested is also included. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
2-1-HALL-WC2	High school; Black water cooler in high school hallway	<1.0	<1.0	N/A		
3-1-GYM-WC1	New gym; Elkay water cooler with bottle filler on back left side of gym; near locker room	<1.0	<1.0	N/A		
3-1-GYM-WC2	New gym; Elkay bottle filler on back left side of gym; near locker room	<1.0	<1.0	N/A		
6-1-ADMIN-WC	Administration building; Avalon black water cooler in closet of administration building	<1.0	<1.0	N/A		

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
8-1-HALL-WC1	Old elementary school; Elkay water cooler in old elementary school hallway; right side	<1.0	<1.0	N/A		
8-1-HALL-WC2	Old elementary school; Elkay water cooler in old elementary school hallway; left side	<1.0	<1.0	N/A		
8-1-HALL-WC3	Old elementary school; White water cooler in old elementary school hallway; used during Covid	<1.0	<1.0	N/A		
9-1-KIT-KF1	Cafeteria building; Kitchen faucet in cafeteria kitchen; corner sink on left	<1.0	<1.0	N/A		
9-1-KIT-IM	Cafeteria building; Manitowoc ice machine in cafeteria kitchen	<1.0	<1.0	N/A		
Low Detection (1.0 - 14.9 µg/L)						
9-1-TL-KF	Cafeteria building; Kitchen faucet in teachers' lounge	<1.0	1.5			
3-1-HALL-WC1	New gym; Elkay water cooler at entrance to gym; on left side	<1.0	2.9			
4-1-HALL-WC2	High school annex building; Elkay water cooler in hallway; right side	<1.0	8.3	Replaced	<1.0	1.3
4-1-HALL-WC1	High school annex building; Elkay water cooler in hallway; left side	<1.0	8.5	Removed	N/A	
5-1-HALL-WC	Old gym; Elkay water cooler in hallway of gym	1.0	<1.0			
9-1-KIT-KF2	Cafeteria building; Kitchen faucet in cafeteria kitchen; sink on wall on left side of kitchen	1.1	<1.0			
2-1-HALL-WC1	High school; Elkay water cooler in high school hallway	1.3	3.4			
3-1-CON-IM	New gym; Ice machine in front concessions stand	2.1	3.2			

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
3-1-GYM-WC3	Elkay water cooler on back right side of gym; near locker room	2.4	10.9	Replaced	<1.0	<1.0
7-1-HALL-WC1	New elementary school; Aspen water cooler in new elementary school building	4.2	3.8			
1-1-AG-WC	Ag building; Elkay water cooler on east side of Ag barn	9.9	8.9	Replaced	1.2	<1.0
3-1-HALL-WC2	New gym; Elkay water cooler at entrance to gym; on right side	10.9	9.2	Replaced	<1.0	<1.0
3-1-CON-KF	New gym; Kitchen faucet in front concessions stand	13.6	<1.0			
High Detection (≥15.0 µg/L)						
5-1-CON-KF	Old gym; Kitchen faucet in concessions stand	67.3	13.3	Replaced	<1.0	<1.0

Building Index

1. Agriculture Barn
2. High School
3. New Gym
4. High School Annex Building
5. Old Gym
6. Administration Building
7. New Elementary School
8. Old elementary School
9. Cafeteria Building